

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Town of Granby South Service Area

Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on 4/26/2023 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
R532 - Monitoring, Recordkeeping, and Data Verification.	Resolved 6/13/2023	Turbidimeters calibrated on March 13th, 2023. Turbidimeters calibrated again on June 12th, 2023. The South Service Area has put standards in place to calibrate turbidimeters every quarter no more than 90 days apart per manufacturer's recommendations. All calibration information showed we are meeting drinking water standards. The South Service Area resolved the violation on June 13th, 2023.

Turbidimeters were calibrated in September of 2021 and again in January of 2022. The turbidimeters should have been calibrated in December of 2021 per manufactures recommendations. In accordance with Regulation 11, Section 11.46, the department expects that turbidimeters be calibrated quarterly as recommended by the manufacturer using primary turbidity standards that have not expired. Not being able to demonstrate that the turbidimeters have been calibrated is a violation of Regulation 11, Section 11.46 and must be corrected.

What does this mean? What should I do?

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We resolved the problem by **June 13th, 2023**. For more information, please contact **Jordan Ennis** at jennis@townofgranby.com or **970-531-5415**, or **PO Box 440 Granby CO 80446**.

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

This notice is being sent to you by: Town of Granby South Service Area - CO0125710
Date distributed: 4/1/2024.